

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No.....407.....

Date: 14/05/2026

It is certified that an inspection team headed by Vikash Kumar, J.E Sikti from A P.H. Sub Division, Araria East inspected the S M PUBLIC SCHOOL, BARDAHA, SIKTI, ARARIA on Dated 14/05/2026 and found that the, S M PUBLIC SCHOOL, BARDAHA, SIKTI, ARARIA has Safe Drinking Water Facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for- One Year

Signature With Seal : Vikash
Name : Vikash Kumar 14/05/2026
Designation : Junior Engineer
P.H. Subdivision Araria East

**Junior Engineer
P.H. Subdivision Araria East**

Letter No: 407

Date:14/05/2026

Government of Bihar
DISTRICT LEVEL WATER TESTING LABORATORY UNDER, PUBLIC HEALTH DIVISION ARARIA.
CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES

District Name:- Araria

Sample Collected By- Jeevan Kumar

Testing Date:14-05-2026

SL. No.	Location of Source	Parameters Examined(Test Result in ppm)													
		pH	TDS	Conductivity	Turbidity	Total Hardness	Calcium	Magnesium	Chloride	Total Alkalinity	Iron	Nitrate	Fluoride	Arsenic	Bacteria
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	S M Public School, Bardaha,Sikti, Araria	6.7	165	253	0.9	105	25	11	32	96	0.32	BDL	-	-	-
BIS 10500:2012 (second revision)	Desireable Limit	6.5-8.5	500	-	1.0	200	75	30	250	200	1.0	45	1.0	0.01	-Ve
	Permissible Limit in absence of alternate source	NR	2000	-	5.0	600	200	100	1000	600	NR	NR	1.5	NR	**

Note (i) BDL means below detection Limit (ii) NR means no relaxation

(Signature)
 14/05/2026
 Chemist (Research Assistant)

P.H.Division,Araria
Research Assistant (Chemist)
 District Laboratory
P.H. Division, Araria

