

SAFE DRINKING WATERNO. 188Date: 13/04/26

It is certified that an Inspection team headed by **UDAY CHAND RAM**, (Name of Officers with designation) from **ASSISTANT ENGINEER, P H. SUB DIVISION , GAYAJI** (Name of department/Office) inspected the **MANAV BHARTI PUBLIC SCHOOL PAHARPUR SHERGHATI DISTRICT – GAYA JI (BIHAR) 824211** (Name & Address of the School) on 02.04.2026 and on the basis of Water Test Report (attached) bearing no. 08/2026.dated 06.04.2026 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till ONE YEAR.

Signature:

Name:..

(UDAY CHAND RAM)

Designation: ASSISTANT ENGINEER

Name & Add. Of Department/

Office: P.H. SUB DIVISION,

GAYA JI WEST, GAYA JI

To,

MANAV BHARTI PUBLIC SCHOOL
PAHARPUR, SHERGHATI
DISTRICT – GAYA JI (BIHAR) 824211
(Name & Address of the Institution)

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :	Pappu kumar	Manav Bharti Public School								Sample Received on : 02/04/26									
Sample no	Block Name	Panchay at Name	Village	Wardno	Turb.	Conducti vity	TDS	Hardnes s	Calcium	Magnesi um	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+,-)	Remarks
1	Amash	Driaura	Pahadpur	-	0.33	690	448	212	67.33	0.264	83.97	236	0.48	7.46	-	-	40	Absent	
Reporting Date :	06.04.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
le Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	
*NR-No Relaxation.,BDL-Below Detection Limit																			

*NR-No Relaxation.,BDL-Below Detection Limit

जल नमूना का संग्रह दिनांक..02.04.26
Pappu kumar के द्वारा किया गया है।

P.H. Division, Gaya
Chemist
02.04.26