SAFE DRINKING WATER

NO. 145

Date: 1715/2025

It is certified that an Inspection team headed by <u>UDAY CHAND RAM</u>, (Name of Officers with designation) from ASSITANT ENGINEER, PH SUB DIVISION, GAYA (Name of department/Office) inspected the <u>BRITISH ENGLISH SCHOOL</u>, VILLAGE - GERE P.O.-MANPUR, P.S.-MUFASSIL DISTRICT- GAYA(BIHAR) (Name & Address of the School) on 28.4.2025 and on the basis of Water Test Report (attached) bearing no. 10/2025.dated 30.4.2025 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till ONE YEAR.

Signature

Name

Designation

सहायक अभियन्ता बोक स्वास्थ्य अवर प्रमंडल

: ASSISTANT ENGINEER

Name & Add. Of Department/Office: P.H

SUB DIVISION, GAYA WEST, GAYA

To

BRITISH ENGLISH SCHOOL,

VILLAGE - GERE
P.O.- MANPUR, P.S.- MUFASSIL
DISTRICT- GAYA (BIHAR) 823003

(Name & Address of the Institution)

Principal
British English School
Gere, Manpur, Gaya (Bihar)

PUBLIC HEALTH ENGINEERING DEPARTMENT GOV. OF BIHAR

Water Quality Test Report P.H.Division, Gaya

1. District- Gaya

2. Block - MANPUR

3. Location Detail - BRITISH ENGLISH SCHOOL (Asecondary School up to 10+2) Mufassil - Gaya

Sampling Date :- 28-04-2025

Testing Date: - 30-04-2025

4. Type Of Source - Deep Tubwell

111	10	9	∞	7	6	5	4	3	2	1	Sino
T.Coliform	TDS	Fluoride	Chloride	Magnesium	Calcum	Total Alkalinity	Total Hardness	Conductivity	рН	Turbidity	PARAMETERS
Absent	500	1	250	30	75	200	200		6.5-8.5	1.0 NTU	Desirable Limit (value in mg/l except pH
Absent	2000	1.5	1000	100	200	600	600	1	No relaxation	5.0 NTU	Alternative Source
Negative	84	0.09	20	9.72	16	80	80	130	7.29	0.07	Water testing result (In mg/l)
							10500:2012)	Indian standard	Analysed sample of water conforms to	Remarks	

Paincipal
British English School
Gere, Manpur, Gaya (Bihar)

Signature of the CHEMIST P.H Division Gaya. Chemist

nammendry kumar 2202 (20/20

P.H. Division, Gaya